



**ADDENDUM No. 2  
ISSUED July 25, 2024**

---

**SEALED BID NO. 2024-SSPR3  
SOUTH SEWALL'S POINT ROAD – PHASE 3  
BID DUE DATE: August 1, 2024 @ 2:00PM**

The following information shall become part of this bid and shall be binding as if originally contained therein.

The items have been included with this addendum:

- Revised Bid Form (file: 2024-SSPR3 Bid Form v2.xlsx)
- Revised Technical Specifications (See Item #15) (file: SSPR PH 3 - tech spec final rev.pdf)

**CONTRACTOR QUESTIONS**

**QUESTION 1:**

Clarification on the bid form: There are many private property 12x12 NDS drains with none shown on the plans. Is this something you are anticipating on having to install and therefore are adding it to the bid form to account for? Therefore, we should include it in our bid. Or is this a different case and these drains and the pipe associated with them should not be included?

**RESPONSE:**

***The yard drains are included in the bid form in anticipation that they will be needed at each private property in a worst-case scenario. Please include it in the bid.***

**QUESTION 2:**

Please clarify the minimum thickness black base for trench repair.

**RESPONSE:**

***The trench repair shall be per the Pavement Replacement Trench Detail on Sheet 27 of the Construction Plans, no black base is required for the trench repair. Trench repair only includes minimum 2' of base rock and a minimum 2" of asphalt.***

**QUESTION 3:**

Is the asphalt base under the curb pad to be paid under the black base (5.5" Type B-12.5) pay item?

**RESPONSE:**

***Please see revised Bid Form and Technical Specifications for clarification, the black base for underneath the curb should be included in the price per linear foot of curbing. The Black Base (Type B-12.5) Pay item is for the roadway only.***



---

Joseph W. Capra, P.E.  
Project Manager

To acknowledge receipt of this **ADDENDUM No. 2**, please sign in the space provided below and **return a copy of this ADDENDUM with the proposal submitted in response to this solicitation.**

**ADDENDUM No. 2** was received on \_\_\_\_\_ by \_\_\_\_\_.  
Date Signature

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Firm Name